
INSTALLATION INSTRUCTIONS VERTICAL CABLE RAILING REPLACEMENT KIT 36" AND 42" SYSTEMS WITH 3" ALUMINUM POSTS



Feed Cable

Determine your application. The angled swage is for stair applications; the other is for deck applications. Use a cut off wheel to remove the unused swage. Feed the replacement cable up through the Bottom Channel, then the Top Channel, leaving the swaged end at the bottom. (Dia. 2)

Prepare Cable End

Move Repair Collar down over top end of cable. Pull slack from the cable and use provide hex wrench to tighten set screw to hold Repair Collar onto Cable. **Note**: a locking pliers may be needed to pull up slack. (Dia. 3)

Tension Cable

Slide Tension Block between Repair Collar and Top Channel with set screw points facing down (Dia. 4)

- · Gently turn set screws just until cable is tight
- Make sure Repair Collar and Tension Block don't stick up over the Top Channel
- **TIP:** Tighten the front set screw first, just until it reaches the channel. Then tighten the rear set screw. This helps to keep everything level. (Dia. 5) **CAUTION:** DO NOT OVER TIGHTEN SET SCREW!
- Stair Applications: Tension blocks must rotate to short angled surface for stair panel applications (Dia. 6). Rotate angled bottom swage to match the angle of the lower rail in stair panel (Dia. 7).

Cut Excess Wire

Use a cut off wheel to cut excess wire flush with top of Repair Collar. (Dia. 8)

Replace Rail Snaps and Support Leg

Reattach the top channel, bottom channel, and center support.

